

Placentia Fire & Life Safety Department
Community Risk Reduction Division
401 E Chapman Avenue
Placentia, CA 92870
(714) 993-8135

**Fire Plan Examination
Submission Requirements**



PLEASE REVIEW THE ENTIRE DOCUMENT

Approved & Authorized By:

Amanda Horner

**Amanda Horner
Fire Marshal**

Date: January 2026

Fire Plan Examination-Submission Requirements

PURPOSE

The purpose of this policy is to provide the developer/contractor information on the fire plan submission requirements for specific fire plan examination of construction documents.

SCOPE

The scope of this policy is to be more specific about the construction documents that are required by the California Fire Code Chapter 9 Section 901.2 in order to conduct a thorough examination of the construction documents for permitting.

SUBMITTAL REQUIREMENTS

1. Electronic Submission

Effective March 1, 2023, Placentia Fire and Life Safety Department will only accept electronic submission of plans that are submitted directly to the Fire Department. Plans and specifications must be submitted in a PDF format to FireCRR@placentia.org PDF files must be set-up and titled as follows:

- A. Completed Fire Plan Application
- B. Fire Construction Plans
- C. Technical Reports from specialized consultants (if required)
- D. Hydraulic Calculations (if required)
- E. Specifications and Cut Sheets
- F. Contractor License and Contact Information

2. Approval Stamp Designated Area on the Construction Plans

There shall be a 6-inch high by 6-inch-wide space provided on the lower right-hand corner of the first page of the construction documents for approval stamps and notes. The box shall be titled – FIRE DEPARTMENT APPROVAL AND NOTES.

3. Turn-around Performance for Fire Plan Examination

The turn-around time for fire plan review varies based on the volume of plans that have been submitted for review. However, we try to maintain a performance benchmark of three-weeks for new submittals and two-weeks for resubmittals. Small tenant improvement projects we attempt to process weekly.

Expedited plan reviews are completed at the discretion of the Fire Marshal based on circumstances and the urgency behind the request. Additional fees may be required to perform an expedited review. A letter of request must be submitted electronically by email to the Fire Marshal requesting an expedited review and providing an explanation as to the reason or need for the expedited review.

4. Plans & Drawings

- A. Plans must be drawn to an architect or engineer scale and the scale must be indicated on the plans.
- B. All plan sheets are to be stamped with the contractor's license stamp and signed.
- C. Applicable codes and standards with the edition/year are to be listed on the plans.
- D. A clear scope of work must be listed on the plans and must be located above the Fire Department Approval and Note area listed in item No. 2 above.
- E. Plans and drawings must be clearly legible and be of sufficient detail/information for the scope of work indicated.
- F. We **do not** accept plans and specifications that are marked as "draft", "not for construction", "for reference only", or "not for permit".
- G. Resubmittals shall indicate changes made by clouding the changes, details or information for clarity and indicated by a delta revision.

5. California Fire Code Chapter 1

The California Fire Code Chapter 1 Section 105.1.1 Permits Required. A property owner or owner's authorized agent who intends to conduct an operation or business or **install or modify systems and equipment** that are regulated by this code, or to cause any such work to be performed, shall first make application to the fire code official and obtain the required permits.

The California Fire Code Chapter 1 Section 105.1.2 (2) Construction permit. A construction permit allows the applicant to **install or modify systems and equipment** for which a permit is required by Section 105.6.

The California Fire Code Chapter 1 Section 113 Violations. Persons who shall fail to comply with any of the requirements thereof or **who shall erect, install, alter, repair or do work in violation of the accepted construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code**, shall be guilty of penalties set forth in PMC O-2025-11.

6. Plan Submission Requirements

- A. UNDERGROUND PRIVATE FIRE SERVICE WATER MAINS (FH's, Backflow, PIV, FDC, etc.)
 - 1. Completed application
 - 2. PFLSD Underground Title Sheet
 - 3. Scaled plans, details and section views
 - 4. Fire flow analysis and calculations – must be dated within the last 6-months)
 - 5. Hydraulic calculations indicating fire flow calculated at 20 PSI for each FH.
 - 6. Product submittal sheets for all equipment used
- B. AUTOMATIC FIRE SPRINKLER SYSTEMS
 - 1. Completed application
 - 2. Scaled plans, details, and section views
 - 3. PFLSD Sprinkler Notes
 - 4. Hydraulic Calculations
 - 5. Fire Flow test results (must be dated within the last 6-months)
 - 6. Product Submittal sheets for all equipment used

7. Technical reports if required of the project

C. AUTOMATIC FIRE ALARM SYSTEMS

1. Completed application
2. PFLSD Alarm System Notes
3. Scaled plans, details, and battery and voltage drop calculations
4. Product submittals for all equipment used
5. California State Fire Marshal listings/approvals (must not be expired)

D. FIXED FIRE SUPPRESSION SYSTEMS

1. Completed application
2. Scaled plans, details, and section views
3. Product submittal manufacturer technical bulletin

E. FIRE PUMPS NOT PART OF AUTOMATIC FIRE SPRINKLER SYSTEM

1. Completed application
2. Scaled plans, details, and section views
3. Hydraulic Calculations
4. Fire Flow test results (must be dated within the last 6-months)
5. Product submittals for all equipment used
6. Electrical permit package submitted through the one-stop permitting center
7. Technical reports, if required of the project

F. CO₂ RELEASE ALARM MONITORING

1. Completed application
2. Scaled plans, details, and section views
3. Product submittals for all equipment used
4. Emergency protocols handbook for the owner (customer)

G. GATES AND BARRICADES ACROSS FIRE APPARATUS ACCESS ROADS

1. Completed application
2. Scaled plans (site plan), details, and section views
3. Product submittals for equipment used specifically indicating UL 325 and ASTM F2200 requirements and compliance
4. Letter of understanding from property owner regarding maintenance and responsibility to ensure immediate action to repair deficiencies at any time

H. EMERGENCY RESPONDER RADIO SYSTEM

1. Completed application
2. Scaled plans, details, section views
3. Scaled plan indicating required grids for field testing
4. Product submittals for all equipment used
5. Minimum qualifications compliance per California Fire Code Chapter 5 Section 510.5.3.
6. The technical criteria found in the California Fire Code Chapter 5 Section 510.4.2.2
7. Standby power requirements per California Fire Code Chapter 5 Section 510.4.2.3

7. Fees for Fire Plan Review/Examination

Fees for plan review/examination will be charged and must be fully paid prior to issuance of a construction permit. Fire plans submitted for review that have not been picked up will be invoiced and required to be paid. If the fire plans submitted are not being installed or the developer has changed contractors, it is incumbent on the contractor who submitted the plans to make written notification of cancellation to the Fire Marshal. If plans have already been reviewed by the fire plans examiner, then the fees will still apply and must be paid.

The fees for fire plan review/examination cover the initial submittal and one resubmittal. Repeated resubmittals will be charged additional fees.

8. Fees for Fire Inspection

Fees for fire inspection of construction projects permitted by Placentia Fire and Life Safety Department will be charged at the same time the fees for fire plan review/examination. All fees are required to be paid in full prior to release of construction permits.

9. Where Do I Pay My Fees

Fees may be paid online via the link on the invoice or in person by credit card, check, or cash at 401 E Chapman Avenue Placentia, CA 92870. Checks shall be made payable to the City of Placentia. Please be sure to include the permit number on the check for cross reference. Please be sure to make a copy of the invoice for the city and attach it with your payment.

10. Construction Permit Issuance

Once the plans have been accepted and all fees have been paid, a construction permit will be issued on the Placentia Fire and Life Safety Department Permit card for the specific system permitted. The construction permit card will be issued at the Development Services Counter located at City hall. The electronic accepted plans will be emailed to the applicant at the email address indicated on the application. Plans and specifications, once accepted, shall not be changed or altered without written approval from Placentia Fire and Life Safety Department. See Section 5 above for penalties that will apply.

The construction permit and hard copy of the accepted plans shall remain on the construction site at all times and be made available to the fire inspector upon request. Failure to provide the permit and/or accepted plans will result in inspection cancellation.

11. Fire Plan Review – Corrections Required

If fire plan review is completed and corrections are required, the plans and a correction letter will be emailed to the applicant listed on the application. Upon resubmission of the corrected plans and specifications the corrections shall be clouded on the plans and indicated by a delta revision and a letter of response must be provided to assist with expediting the resubmission review process.

12. Plan Amendment

A plan amendment is required when a fire inspector performs a fire inspection and changes have been made in the field that are not minor in nature and require further fire plan examination to verify that code requirements are in compliance. Plan amendments require additional fees to be paid. The fire inspector will decide if the project requires a plan amendment

and direct the contractor accordingly. If a plan amendment is required, the fire inspector will not sign off on any inspection or test being performed at that time until the plan amendment acceptance has been provided.

13. As Built Plans

An as built plan is required when field modifications of a minor nature have been made and the fire inspector can make the determination that the codes and standards have been met. As built plans are for minor changes only and are within the fire inspector's scope of authority. As built plans must be submitted and marked as an "AS BUILT PLAN" with the date and submitted electronically referencing the F-Permit Number. These will be kept on record for future reference.